

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OF MEMO TO FILE

DATE April 19, 1977

DEPARTMENT _____

Re: Ozark Welding & Supply
3016 W. Chestnut Exp.

Bob Schaefer called this office and wanted Bob Corson and I to field check plans for improvements at the above business. In question were two pit areas with floor drains in them. We contacted the manager and were told that one pit would be used exclusively for pressure testing compressed air tanks and that only water would be used. The second pit is for a large scale with which to weigh cylinders. One remaining pit, to be under the loading dock, was to be covered. Schaefer agreed that there seemed to be no problems, other than that they would be required to attach the new sewer line to an existing house line or existing wye.

3016 W. CHESTNUT EXP.

SIGNED



John Witherspoon, WPCI II, S & E